







Technical Requirment

1. Weight:1900kg(with gas);gas weight:10kg.
2. Foundation load:Static(downward):1900kg;
   Dynamic horizontal:1500kg;
   Vertical direction(upward):2500kg.
3. The surface levelness of concrete is not greater than 1.5mm.
4. Terminal board material:aluminium alloy .
5. Wind area:4.2m² ;Natural frequency:2.0Hz.

Terminal (UP)
1 : 10



Terminal (BELOW)
1 : 10



B-B



C-C



A1 0 50 F 150 250
A3 0 100 300 500
ALL DIMENSIONS IN MILLIMETERS
UNLESS OTHERWISE NOTED

REV.No	Date	Description	Design	Check	Review	Approved

CB Outline and Foundation Base
Installed Base Drawing
断路器外形及地基图

FOR APPROVAL

CHINT ELECTRIC
Power Transmission & Distribution
3255 Sixian Road
Songjiang District
Shanghai China
Tel: +86 21 6777 7777
Fax: +86 21 6777 7722

© COPYRIGHT CHINT ELECTRIC CO., LTD

PROJECT NAME
拉美洲巴西 - COOPERA_ELETROCAR CT, VT & SA

DESIGN		DATE	
CHECK		DATE	
REVIEW		DATE	
APPROVED		SCALE	1:40

TYPE LW36-145 REV. 01
DOC.NO SHEET 01 / 01